Public Works (1910) Department.

G.O., No. 1619

DATED 26/5/1910.

[Despatch Abstract.]

Lascars' shed at the Peranai Regulator.

Approving a proposal to construct at a cost of Rs 580, a ——, and returning the estimate to the S.E.C. Circle for disposal.

30/5/10.

Indexed.

Government of Madras.

PUBLIC WORKS DEPARTMENT.

IRRIGATION.
ACCOUNT.

Recd. } 1910. *Enclosures*

Regd. *Spare copies*

G.O., No. 161 I., 25th May 1910.

Lascar's shed at the Peranai Regulator

Approving a proposal to construct, at a cost of Rs. 580, a —, and returning the estimate to the Superintending Engineer, VI Circle, for disposal.

No. 161 I., 25TH MAY 1910.

GOVERNMENT OF MADRAS.

PUBLIC WORKS DEPARTMENT.

Irrigation.
Account.

READ—the following papers :—

I

Letter—from T. W. S. SMYTH, Esq., Superintending Engineer, VI Circle.
To—the Chief Engineer for Irrigation.
Dated—Camp, Periyakulam, the 1st May 1910.
No.—473-C.E.

I have the honour to forward herewith, for your approval and sanction of Government, an estimate, amounting to Rs. 580, for constructing a lascar's shed at Peranai near the Regulator as shown on the site survey plan No. M. 33/1910.

The design of the hut is an ordinary one and calls for no special remarks, and the necessity for the hut is clearly explained in the report attached to the estimate.

As the work will have to be completed before the next rainy season, early sanction to the estimate is requested.

ENCLOSURE.

Report to accompany the estimate for constructing a lascar's shed at Peranai Regulator.

		RS.
Amount of estimate	... ...	580

During the flood season, it is absolutely necessary that the turn lascars should remain near the Regulator day and night as the river rises very suddenly and the Regulator shutters must be worked at once. The old temporary shed was blown down last year and it is now proposed to build a permanent one. The old thatched temporary shed besides, is very unsightly and untidy. This estimate therefore provides for the construction of a new masonry shed near the Regulator as per plan enclosed. The stones available in the demolished head sluice of Peranai will be used for this work. The roof will be of flat and pan tiles with chunam borders over junglewood rafters. A narrow front verandah will be provided to take away, somewhat from the otherwise very plain and unornamental appearance of the building. The work will be neatly finished off so that it may not be an eyesore like the present temporary shed. The flooring throughout will be on 4″ concrete with cement plastering.

A small store room is allowed for tools, etc.

Early sanction is requested so that the shed may be ready for use before the rainy season sets in.

J. M. M. PARKER,
Executive Engineer, Madura division.

II

Note by the Chief Engineer for Irrigation, dated 19th May 1910.

The proposal to construct a lascar's shed at the Peranai Regulator, at a cost of Rs. 580, may be approved and the estimate returned to the Superintending Engineer for disposal as it is within his powers of sanction.

C. A. SMITH,
Chief Engineer for Irrigation.

Order—No. 161 I., dated 25th May 1910.

The recommendation of the Chief Engineer for Irrigation is approved, and the estimate for the work in question will be returned to the Superintending Engineer, VI Circle, for disposal.

(True Extract.)

C. A. SMITH,
Joint Secretary to Govt., P.W.D.,
Irrigation Branch.

To the Chief Engineer for Irrigation.
,, Superintending Engineer, VI Circle, with plans and estimates.
,, Examiner, Public Works Accounts.

Forwarded to the

(By Order.)

Deputy Registrar.

2,000—30-4-90.

Subject :—

P.W.D. Irrigation Branch.

NOTES

CONNECTED WITH

G.O., No. I., dated 19 .

Notes edited.

Initials of the Clerk.

Subject

Estimate amtg to Rs 580 for constg a lascar's shed at Peranai near the Regulator

Current No 1973/10 From the Supdg: Engineer ~~Fifth~~ Circle No 473 CE dt 10th May 1910

D. I.

The necessity for the shed is explained in the report. (Page 3 C file)

2. For orders whether the estimate may be checked for sanction

[illegible] 15-5-10 [illegible] 15.5.10

2. I

For orders

[signature]
16-5-10

To be checked at once for sanction (at Ooty if possible)

[signature]
16/5

CONFIDENTIAL No. 5020
PASSED ON BY } 23-5-10
R. C.
U. R. C.
S.
R. K.
D. O.

PUBLIC WORKS DEPARTMENT,
IRRIGATION BRANCH.

PROCEEDINGS OF THE MADRAS GOVERNMENT.

Encs 3+2 plans = 5

READ the following

From the Supg. Engr. VI Circle No. 473 CE d. 1-5-1910.

Print with report

3P

Note by the E.D.

The proposal to ~~The estimate of Rs 580 for~~ Constructing a lascar's shed at the Peranai Regulator at a cost of Rs 580 may be approved and the estimate returned to the Supg. Engineer for disposal as it is within his powers of sanction.

Order No. 1618 I/25-5-10.

The recommendation of the Chief Engineer for Irrigation is approved and the estimate for the work in question will be returned to the Superintending Engineer VI Circle for disposal.

Issue

To

The Chief Engr for Irrigⁿ ✓ Despd 26/5/10
" Supg. Engr VI Circle with plans & estes encls ✓
" Examiner PW Accts ✓ Despd 27/5/10

May 19.5.10

19.5-10 DT

19/5

I

Ord. Press

24-5-10

F. S. 9.

Please see if the draft order is correct

Ino
19/5/10

Seen

M.h. 21.5.10

D.S.

The Estimate has been checked and the following points are brought to notice and orders thereon:–

1. Roofing. Report says simply that× jungle wood will be used for rafters &c. The name of the wood is not given, and information about the safe allowable stresses for the wood in question is not known. But the Scantlings proposed seem suitable.

× p 3 of C.f.

2. Soil & Subsoil. Particulars as to the nature of Soil & Sub soil are not furnished as required in Cir Memo No $\frac{4257\text{-C}}{30.9.04}$ ~~here~~ (Copy put up).

The site is obviously on made soil probably sand. This is evident from the site plan. Need not be mentioned in E.E.'s Note

Fig A
× Since removed

3. Rates. The Rates are not supported by any data accompanying the Estimate.

The low rates for (a) Concrete stone jelly in mortar Rs 10 per unit, (b) Coursed rubble in mortar Rs 11, (c) Coursed rubble in mud are apparently due to old stones from the Demolished Peranai Hd: sluice, being used for the work. It is also submitted that in the absence of Schedules of Rates at Ooty other rates in the Est: susceptible of any check here.

vide Report p 3 of C.f

For orders, (1) Whether S.E's rates may be accepted as Correct and draft order prepared, or (2) if a reference to Madras office be made about the verification of these rates.

KP
18.5.10

E. I

The est may be sanctioned although two E W circulars have not been complied with. The work is however small. I would suggest for the comfort of the occupant that the walls might be of country brick in mud. This would perhaps be done for the same cost. & the walls might be made 1½ brick abt 13" instead of 1½'. A stone building is hot in the hot weather & cold in the cold.

[signature]
18/5/10

This will only cause delay as old stone available at site is being used. I have never known a lascar complain of a stone shed. [initials] 18/5

Heat
Conducting power
Slate 1,000
Flagstone 1110 -
Portland stone 750
Brick. 600 & 720.
Lath & plaster 255
Mole. wall.

Sanction est as it stands
[initials]
18/5/10

~~H.D. Please put up a note by E.I. embodying the tech points. mso 18.5.10~~

~~H.C. I have put in a draft note by E.I. It is better to have it typed on D.I's approval of the same. [initials] 19/5/10~~

D.I.

A draft order is put up for approval
mso
19.5.10

[signature]. I.
19-5-10

40-14

Val
farneto
1946